The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

ORTTYPEC	CITYTOWN	ORG CODE	SCHOOL NAME	SCHOOL TYPE	OCATION I	SAMPLE LOCATION NAME	PLECOMM	NALYTENAN	RESULT	S OF MEASURE	D DETECTI	CAL METH	ANALYSIS LAB	LAB SAMPLE ID	YSISCOMM	SAMPLER NAME	MPLE COLLECTION DA	E COLLECTIO	REPORT DATE
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	001F	ROOM 1 FAUCET		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293302		J. SCOUPONETI	11/8/2016	07:05:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	001F	ROOM 1 FAUCET		COPPER	0.06	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293302		J. SCOUPONETI	11/8/2016	07:05:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	001P	ROOM 1 FAUCET		LEAD	0.006	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293301		J. SCOUPONETI	11/8/2016	07:05:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	001P	ROOM 1 FAUCET		COPPER	0.08	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293301		J. SCOUPONETI	11/8/2016	07:05:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	002P	ROOM 1 BUBBLER		LEAD	0.002	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293303		J. SCOUPONETI	11/8/2016	07:05:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	002P	ROOM 1 BUBBLER		COPPER	0.12	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293303		J. SCOUPONETI	11/8/2016	07:05:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	003F	ROOM 3 FAUCET		LEAD	ND	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293305		J. SCOUPONETI	11/8/2016	07:11:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	003F	ROOM 3 FAUCET		COPPER	0.07	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293305		J. SCOUPONETI	11/8/2016	07:11:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	003P	ROOM 3 FAUCET		LEAD	0.002	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293304		J. SCOUPONETI	11/8/2016	07:11:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	003P	ROOM 3 FAUCET		COPPER	0.09	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293304		J. SCOUPONETI	11/8/2016	07:11:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	004P	ROOM 3 BUBBLER		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293306		J. SCOUPONETI	11/8/2016	07:11:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	004P	ROOM 3 BUBBLER		COPPER	0.08	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293306		J. SCOUPONETI	11/8/2016	07:11:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	005F	ROOM 5 FAUCET		LEAD	0.002	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293308		J. SCOUPONETI	11/8/2016	07:16:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	005F	ROOM 5 FAUCET		COPPER	0.12	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293308		J. SCOUPONETI	11/8/2016	07:16:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	005P	ROOM 5 FAUCET		LEAD	0.013	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293307		J. SCOUPONETI	11/8/2016	07:16:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	005P	ROOM 5 FAUCET		COPPER	0.14	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293307		J. SCOUPONETI	11/8/2016	07:16:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	006P	ROOM 5 BUBBLER		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293309		J. SCOUPONETI	11/8/2016	07:16:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	006P	ROOM 5 BUBBLER		COPPER	0.13	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293309		J. SCOUPONETI	11/8/2016	07:16:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	007F	ROOM 7 FAUCET		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293311		J. SCOUPONETI	11/8/2016	07:21:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	007F	ROOM 7 FAUCET		COPPER	0.16	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293311		J. SCOUPONETI	11/8/2016	07:21:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	007P	ROOM 7 FAUCET		LEAD	0.022	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293310		J. SCOUPONETI	11/8/2016	07:21:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	007P	ROOM 7 FAUCET		COPPER	0.10	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293310		J. SCOUPONETI	11/8/2016	07:21:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	008P	ROOM 7 BUBBLER		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293312		J. SCOUPONETI	11/8/2016	07:21:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	008P	ROOM 7 BUBBLER		COPPER	0.18	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293312		J. SCOUPONETI	11/8/2016	07:21:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	009F	ROOM 9 FAUCET		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293314		J. SCOUPONETI	11/8/2016	07:26:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	009F	ROOM 9 FAUCET		COPPER	0.18	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293314		J. SCOUPONETI	11/8/2016	07:26:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	009P	ROOM 9 FAUCET		LEAD	0.003	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293313		J. SCOUPONETI	11/8/2016	07:26:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	009P	ROOM 9 FAUCET		COPPER	0.21	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293313		J. SCOUPONETI	11/8/2016	07:26:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	010P	ROOM 9 BUBBLER		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293315		J. SCOUPONETI	11/8/2016	07:26:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	010P	ROOM 9 BUBBLER		COPPER	0.18	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293315		J. SCOUPONETI	11/8/2016	07:26:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	011F	ROOM 8 FAUCET		LEAD	ND	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293317		J. SCOUPONETI	11/8/2016	07:36:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	011F	ROOM 8 FAUCET		COPPER	0.15	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293317		J. SCOUPONETI	11/8/2016	07:36:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	011P	ROOM 8 FAUCET		LEAD	0.004	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293316		J. SCOUPONETI	11/8/2016	07:36:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	011P	ROOM 8 FAUCET		COPPER	0.17	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293316		J. SCOUPONETI	11/8/2016	07:36:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	012P	ROOM 8 BUBBLER		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293318		J. SCOUPONETI	11/8/2016	07:36:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	012P	ROOM 8 BUBBLER		COPPER	0.15	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293318		J. SCOUPONETI	11/8/2016	07:36:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	013F	ROOM 6 FAUCET		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293320		J. SCOUPONETI	11/8/2016	07:40:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	013F	ROOM 6 FAUCET		COPPER	0.10	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293320		J. SCOUPONETI	11/8/2016	07:40:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	013P	ROOM 6 FAUCET		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293319		J. SCOUPONETI	11/8/2016	07:40:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	013P	ROOM 6 FAUCET		COPPER	0.14	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293319		J. SCOUPONETI	11/8/2016	07:40:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	014P	ROOM 6 BUBBLER		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293321		J. SCOUPONETI	11/8/2016	07:40:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	014P	ROOM 6 BUBBLER		COPPER	0.10	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293321		J. SCOUPONETI	11/8/2016	07:40:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	015F	ROOM 4 FAUCET		LEAD	0.002	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293323		J. SCOUPONETI	11/8/2016	07:44:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	015F	ROOM 4 FAUCET		COPPER	0.08	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293323		J. SCOUPONETI	11/8/2016	07:44:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	015P	ROOM 4 FAUCET		LEAD	0.024	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293322		J. SCOUPONETI	11/8/2016	07:44:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	015P	ROOM 4 FAUCET		COPPER	0.06	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293322		J. SCOUPONETI	11/8/2016	07:44:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	016P	ROOM 4 BUBBLER		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293324		J. SCOUPONETI	11/8/2016	07:44:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	016P	ROOM 4 BUBBLER		COPPER	0.09	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293324		J. SCOUPONETI	11/8/2016	07:44:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	017F	ROOM 2 FAUCET		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293326		J. SCOUPONETI	11/8/2016	07:52:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	017F	ROOM 2 FAUCET		COPPER	0.06	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293326		J. SCOUPONETI	11/8/2016	07:52:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	017P	ROOM 2 FAUCET		LEAD	0.010	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293325		J. SCOUPONETI	11/8/2016	07:52:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	017P	ROOM 2 FAUCET		COPPER	0.40	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293325		J. SCOUPONETI	11/8/2016	07:52:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	018P	ROOM 2 BUBBLER		LEAD	0.007	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293327		J. SCOUPONETI	11/8/2016	07:52:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	018P	ROOM 2 BUBBLER		COPPER	0.08	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293327		J. SCOUPONETI	11/8/2016	07:52:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	019F	ROOM 12 FAUCET		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293601		J. SCOUPONETI	11/8/2016	07:57:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	019F	ROOM 12 FAUCET		COPPER	0.09	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293601		J. SCOUPONETI	11/8/2016	07:57:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	019P	ROOM 12 FAUCET		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293328		J. SCOUPONETI	11/8/2016	07:57:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	019P	ROOM 12 FAUCET		COPPER	0.08	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293328		J. SCOUPONETI	11/8/2016	07:57:00	03-Jan-17

LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	020F	ROOM 25 FAUCET		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293603		J. SCOUPONETI	11/8/2016	08:01:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	020F	ROOM 25 FAUCET		COPPER	0.15	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293603		J. SCOUPONETI	11/8/2016	08:01:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	020P	ROOM 25 FAUCET		LEAD	0.004	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293602		J. SCOUPONETI	11/8/2016	08:01:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	020P	ROOM 25 FAUCET		COPPER	0.28	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293602		J. SCOUPONETI	11/8/2016	08:01:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	021F	ROOM 26 FAUCET		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293605		J. SCOUPONETI	11/8/2016	08:04:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	021F	ROOM 26 FAUCET		COPPER	0.05	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293605		J. SCOUPONETI	11/8/2016	08:04:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	021P	ROOM 26 FAUCET		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293604		J. SCOUPONETI	11/8/2016	08:04:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	021P	ROOM 26 FAUCET		COPPER	0.15	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293604		J. SCOUPONETI	11/8/2016	08:04:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	022F	ROOM 15 FAUCET		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293607		J. SCOUPONETI	11/8/2016	08:07:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	022F	ROOM 15 FAUCET		COPPER	0.05	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293607		J. SCOUPONETI	11/8/2016	08:07:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	022P	ROOM 15 FAUCET		LEAD	0.005	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293606		J. SCOUPONETI	11/8/2016	08:07:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	022P	ROOM 15 FAUCET		COPPER	0.09	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293606		J. SCOUPONETI	11/8/2016	08:07:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	023P	ROOM 15 BUBBLER		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293608		J. SCOUPONETI	11/8/2016	08:07:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	023P	ROOM 15 BUBBLER		COPPER	0.05	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293608		J. SCOUPONETI	11/8/2016	08:07:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	024F	ROOM 17 FAUCET		LEAD	ND	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293610		J. SCOUPONETI	11/8/2016	08:12:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	024F	ROOM 17 FAUCET		COPPER	0.10	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293610		J. SCOUPONETI	11/8/2016	08:12:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	024P	ROOM 17 FAUCET		LEAD	0.013	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293609		J. SCOUPONETI	11/8/2016	08:12:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	024P	ROOM 17 FAUCET		COPPER	0.14	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293609		J. SCOUPONETI	11/8/2016	08:12:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	025P	ROOM 17 BUBBLER		LEAD	0.002	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293611		J. SCOUPONETI	11/8/2016	08:12:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	025P	ROOM 17 BUBBLER		COPPER	0.13	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293611		J. SCOUPONETI	11/8/2016	08:12:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	026F	ROOM 19 FAUCET		LEAD	ND	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293613		J. SCOUPONETI	11/8/2016	08:17:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	026F	ROOM 19 FAUCET		COPPER	0.16	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293613		J. SCOUPONETI	11/8/2016	08:17:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	026P	ROOM 19 FAUCET		LEAD	0.002	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293612		J. SCOUPONETI	11/8/2016	08:17:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	026P	ROOM 19 FAUCET		COPPER	0.14	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293612		J. SCOUPONETI	11/8/2016	08:17:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	027P	ROOM 19 BUBBLER		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293614		J. SCOUPONETI	11/8/2016	08:17:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	027P	ROOM 19 BUBBLER		COPPER	0.19	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293614		J. SCOUPONETI	11/8/2016	08:17:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	028F	ROOM 21 FAUCET		LEAD	ND	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293616		J. SCOUPONETI	11/8/2016	08:22:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	028F	ROOM 21 FAUCET		COPPER	0.19	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293616		J. SCOUPONETI	11/8/2016	08:22:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	028P	ROOM 21 FAUCET		LEAD	0.003	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293615		J. SCOUPONETI	11/8/2016	08:22:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	028P	ROOM 21 FAUCET		COPPER	0.16	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293615		J. SCOUPONETI	11/8/2016	08:22:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	029P	ROOM 21 BUBBLER		LEAD	ND	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293617		J. SCOUPONETI	11/8/2016	08:22:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	029P	ROOM 21 BUBBLER		COPPER	0.19	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293617		J. SCOUPONETI	11/8/2016	08:22:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	030F	ROOM 20 FAUCET		LEAD	ND	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293619		J. SCOUPONETI	11/8/2016	08:27:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	030F	ROOM 20 FAUCET		COPPER	0.12	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293619		J. SCOUPONETI	11/8/2016	08:27:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	030P	ROOM 20 FAUCET		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293618		J. SCOUPONETI	11/8/2016	08:27:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	030P	ROOM 20 FAUCET		COPPER	0.15	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293618		J. SCOUPONETI	11/8/2016	08:27:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	031P	ROOM 20 BUBBLER		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293620		J. SCOUPONETI	11/8/2016	08:27:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	031P	ROOM 20 BUBBLER		COPPER	0.12	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293620		J. SCOUPONETI	11/8/2016	08:27:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	032F	ROOM 18 FAUCET		LEAD	ND	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293622		J. SCOUPONETI	11/8/2016	08:37:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	032F	ROOM 18 FAUCET		COPPER	0.06	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293622		J. SCOUPONETI	11/8/2016	08:37:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	032P	ROOM 18 FAUCET		LEAD	0.002	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293621		J. SCOUPONETI	11/8/2016	08:37:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	032P	ROOM 18 FAUCET		COPPER	0.13	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293621		J. SCOUPONETI	11/8/2016	08:37:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	033P	ROOM 18 BUBBLER		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293623		J. SCOUPONETI	11/8/2016	08:37:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	033P	ROOM 18 BUBBLER		COPPER	0.07	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293623		J. SCOUPONETI	11/8/2016	08:37:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	034F	ROOM 16 FAUCET		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293625		J. SCOUPONETI	11/8/2016	08:41:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	034F	ROOM 16 FAUCET		COPPER	0.05	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293625		J. SCOUPONETI	11/8/2016	08:41:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	034P	ROOM 16 FAUCET		LEAD	0.005	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293624		J. SCOUPONETI	11/8/2016	08:41:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	034P	ROOM 16 FAUCET		COPPER	0.13	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293624		J. SCOUPONETI	11/8/2016	08:41:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	035P	ROOM 16 BUBBLER		LEAD	0.002	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293626		J. SCOUPONETI	11/8/2016	08:41:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	035P	ROOM 16 BUBBLER		COPPER	0.05	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293626		J. SCOUPONETI	11/8/2016	08:41:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	036F	ROOM 14 FAUCET		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293628		J. SCOUPONETI	11/8/2016	08:46:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	036F	ROOM 14 FAUCET		COPPER	0.11	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293628		J. SCOUPONETI	11/8/2016	08:46:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	036P	ROOM 14 FAUCET		LEAD	0.008	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293627		J. SCOUPONETI	11/8/2016	08:46:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	036P	ROOM 14 FAUCET		COPPER	0.14	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293627		J. SCOUPONETI	11/8/2016	08:46:00	28-Dec-16
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	037P	ROOM 14 BUBBLER		LEAD	0.003	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293901		J. SCOUPONETI	11/8/2016	08:46:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	037P	ROOM 14 BUBBLER		COPPER	0.09	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293901		J. SCOUPONETI	11/8/2016	08:46:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	038F	BUBBLER YELLOW HALL		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293903		J. SCOUPONETI	11/8/2016	08:50:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	038F	BUBBLER YELLOW HALL		COPPER	0.05	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293903		J. SCOUPONETI	11/8/2016	08:50:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	038P	BUBBLER YELLOW HALL		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293902		J. SCOUPONETI	11/8/2016	08:50:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	038P	BUBBLER YELLOW HALL		COPPER	0.07	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293902		J. SCOUPONETI	11/8/2016	08:50:00	03-Jan-17

LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	039F	FAUCET DISHWASHER ROOM		LEAD	0.002	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293905		J. SCOUPONETI	11/8/2016	08:53:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	039F	FAUCET DISHWASHER ROOM		COPPER	0.22	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293905		J. SCOUPONETI	11/8/2016	08:53:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	039P	FAUCET DISHWASHER ROOM		LEAD	0.016	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293904		J. SCOUPONETI	11/8/2016	08:53:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	039P	FAUCET DISHWASHER ROOM		COPPER	0.12	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293904		J. SCOUPONETI	11/8/2016	08:53:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	040F	KITCHEN FAUCET 3 BAY SINK		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293907		J. SCOUPONETI	11/8/2016	08:56:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	040F	KITCHEN FAUCET 3 BAY SINK		COPPER	0.04	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293907		J. SCOUPONETI	11/8/2016	08:56:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	040P	KITCHEN FAUCET 3 BAY SINK		LEAD	0.008	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293906		J. SCOUPONETI	11/8/2016	08:56:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	040P	KITCHEN FAUCET 3 BAY SINK		COPPER	0.14	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293906		J. SCOUPONETI	11/8/2016	08:56:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	041F	KITCHEN FAUCET SINGLE BAY SINK		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293909		J. SCOUPONETI	11/8/2016	08:59:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	041F	KITCHEN FAUCET SINGLE BAY SINK		COPPER	0.04	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293909		J. SCOUPONETI	11/8/2016	08:59:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	041P	KITCHEN FAUCET SINGLE BAY SINK		LEAD	0.004	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293908		J. SCOUPONETI	11/8/2016	08:59:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	041P	KITCHEN FAUCET SINGLE BAY SINK		COPPER	0.08	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293908		J. SCOUPONETI	11/8/2016	08:59:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	042F	KITCHEN FAUCET BY WASHING MACHINE		LEAD	0.004	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293911		J. SCOUPONETI	11/8/2016	09:01:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	042F	KITCHEN FAUCET BY WASHING MACHINE		COPPER	0.07	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293911		J. SCOUPONETI	11/8/2016	09:01:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	042P	KITCHEN FAUCET BY WASHING MACHINE		LEAD	0.071	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293910		J. SCOUPONETI	11/8/2016	09:01:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	042P	KITCHEN FAUCET BY WASHING MACHINE		COPPER	0.19	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293910		J. SCOUPONETI	11/8/2016	09:01:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	043F	KITCHEN KETTLE COLD		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293913		J. SCOUPONETI	11/8/2016	09:03:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	043F	KITCHEN KETTLE COLD		COPPER	0.03	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293913		J. SCOUPONETI	11/8/2016	09:03:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	043P	KITCHEN KETTLE COLD		LEAD	0.006	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293912		J. SCOUPONETI	11/8/2016	09:03:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	043P	KITCHEN KETTLE COLD		COPPER	0.16	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293912		J. SCOUPONETI	11/8/2016	09:03:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	044F	WATER COOLER @ ENTRANCE OF CAF?		LEAD	ND	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293915		J. SCOUPONETI	11/8/2016	09:06:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	044F	WATER COOLER @ ENTRANCE OF CAF?		COPPER	0.15	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293915		J. SCOUPONETI	11/8/2016	09:06:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	044P	WATER COOLER @ ENTRANCE OF CAF?		LEAD	ND	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293914		J. SCOUPONETI	11/8/2016	09:06:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	044P	WATER COOLER @ ENTRANCE OF CAF?		COPPER	0.22	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293914		J. SCOUPONETI	11/8/2016	09:06:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	045F	ROOM 27 FAUCET		LEAD	0.002	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293917		J. SCOUPONETI	11/8/2016	09:11:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	045F	ROOM 27 FAUCET		COPPER	0.06	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293917		J. SCOUPONETI	11/8/2016	09:11:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	045P	ROOM 27 FAUCET		LEAD	0.009	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293916		J. SCOUPONETI	11/8/2016	09:11:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	045P	ROOM 27 FAUCET		COPPER	0.19	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293916		J. SCOUPONETI	11/8/2016	09:11:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	046F	BUBBLER OUTSIDE OF OFFICE		LEAD	ND	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293919		J. SCOUPONETI	11/8/2016	09:13:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	046F	BUBBLER OUTSIDE OF OFFICE		COPPER	0.08	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293919		J. SCOUPONETI	11/8/2016	09:13:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	046P	BUBBLER OUTSIDE OF OFFICE		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293918		J. SCOUPONETI	11/8/2016	09:13:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	046P	BUBBLER OUTSIDE OF OFFICE		COPPER	0.12	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293918		J. SCOUPONETI	11/8/2016	09:13:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	047F	NURSE CLINIC		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293921		J. SCOUPONETI	11/8/2016	09:16:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	047F	NURSE CLINIC		COPPER	0.06	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293921		J. SCOUPONETI	11/8/2016	09:16:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	047P	NURSE CLINIC		LEAD	0.002	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293920		J. SCOUPONETI	11/8/2016	09:16:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	047P	NURSE CLINIC		COPPER	0.09	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293920		J. SCOUPONETI	11/8/2016	09:16:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	048F	BUBBLER IN GYM		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293923		J. SCOUPONETI	11/8/2016	09:18:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	048F	BUBBLER IN GYM		COPPER	0.06	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293923		J. SCOUPONETI	11/8/2016	09:18:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	048P	BUBBLER IN GYM		LEAD	0.001	MG/L	0.001	EPA 200.8	ANALYTICAL BALANCE CORP	169293922		J. SCOUPONETI	11/8/2016	09:18:00	03-Jan-17
LCCA	Marshfield	01710005	Marshfield: Eames Way School	Public School	048P	BUBBLER IN GYM		COPPER	0.08	MG/L	0.02	EPA 200.8	ANALYTICAL BALANCE CORP	169293922		J. SCOUPONETI	11/8/2016	09:18:00	03-Jan-17