

The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

PORTTYPE	CITY/TOWN	ORG CODE	SCHOOL NAME	SCHOOL TYPE	LOCATION ID	SAMPLE LOCATION NAME	AMPLE COMMENT	ANALYTE NAME	RESULT	OF MEASURE	METHOD DETECTION LIMIT	YTICAL METHOD	ALYSIS	LAB SAMPLE ID	ANALYSIS COMMENTS	SAMPLER NAME	SAMPLE COLLECTION DATE	LE COLLECTION	REPORT DATE
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	001F	KITCHEN RINSE SINK		COPPER	ND	MG/L	0.02	EPA 200.8	ICAL BALAN	169291102		A. BUNTEN	11/8/2016	10:22:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	001F	KITCHEN RINSE SINK		LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291102		A. BUNTEN	11/8/2016	10:22:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	001P	KITCHEN RINSE SINK		COPPER	0.03	MG/L	0.02	EPA 200.8	ICAL BALAN	169291101		A. BUNTEN	11/8/2016	10:26:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	001P	KITCHEN RINSE SINK		LEAD	0.001	MG/L	0.001	EPA 200.8	ICAL BALAN	169291101		A. BUNTEN	11/8/2016	10:26:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	002F	KITCHEN KETTLE COLD		COPPER	ND	MG/L	0.02	EPA 200.8	ICAL BALAN	169291104		A. BUNTEN	11/8/2016	10:23:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	002F	KITCHEN KETTLE COLD		LEAD	0.001	MG/L	0.001	EPA 200.8	ICAL BALAN	169291104		A. BUNTEN	11/8/2016	10:23:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	002P	KITCHEN KETTLE COLD		COPPER	0.04	MG/L	0.02	EPA 200.8	ICAL BALAN	169291103		A. BUNTEN	11/8/2016	10:22:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	002P	KITCHEN KETTLE COLD		LEAD	0.001	MG/L	0.001	EPA 200.8	ICAL BALAN	169291103		A. BUNTEN	11/8/2016	10:22:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	003P	WATER COOLER LEFT OUTSIDE RM 10		COPPER	0.03	MG/L	0.02	EPA 200.8	ICAL BALAN	169291105		A. BUNTEN	11/8/2016	10:25:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	003P	WATER COOLER LEFT OUTSIDE RM 10		LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291105		A. BUNTEN	11/8/2016	10:25:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	004F	WATER COOLER RIGHT OUTSIDE RM 10		COPPER	0.03	MG/L	0.02	EPA 200.8	ICAL BALAN	169291107		A. BUNTEN	11/8/2016	10:26:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	004F	WATER COOLER RIGHT OUTSIDE RM 10		LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291107		A. BUNTEN	11/8/2016	10:26:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	004P	WATER COOLER RIGHT OUTSIDE RM 10		COPPER	0.04	MG/L	0.02	EPA 200.8	ICAL BALAN	169291106		A. BUNTEN	11/8/2016	10:26:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	004P	WATER COOLER RIGHT OUTSIDE RM 10		LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291106		A. BUNTEN	11/8/2016	10:26:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	005P	WATER BUBBLER LEFT OUTSIDE RM 22		COPPER	0.03	MG/L	0.02	EPA 200.8	ICAL BALAN	169291108		A. BUNTEN	11/8/2016	10:27:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	005P	WATER BUBBLER LEFT OUTSIDE RM 22		LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291108		A. BUNTEN	11/8/2016	10:27:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	006F	WATER BUBBLER RIGHT OUTSIDE RM 22		COPPER	0.02	MG/L	0.02	EPA 200.8	ICAL BALAN	169291110		A. BUNTEN	11/8/2016	10:30:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	006F	WATER BUBBLER RIGHT OUTSIDE RM 22		LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291110		A. BUNTEN	11/8/2016	10:30:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	006P	WATER BUBBLER RIGHT OUTSIDE RM 22		COPPER	0.02	MG/L	0.02	EPA 200.8	ICAL BALAN	169291109		A. BUNTEN	11/8/2016	10:30:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	006P	WATER BUBBLER RIGHT OUTSIDE RM 22		LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291109		A. BUNTEN	11/8/2016	10:30:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	007P	WATER BUBBLER LEFT AUDITORIUM LOBBY		COPPER	0.02	MG/L	0.02	EPA 200.8	ICAL BALAN	169291111		A. BUNTEN	11/8/2016	10:32:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	007P	WATER BUBBLER LEFT AUDITORIUM LOBBY		LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291111		A. BUNTEN	11/8/2016	10:32:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	008F	WATER BUBBLER RIGHT AUDITORIUM LOBBY		COPPER	ND	MG/L	0.02	EPA 200.8	ICAL BALAN	169291113		A. BUNTEN	11/8/2016	10:34:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	008F	WATER BUBBLER RIGHT AUDITORIUM LOBBY		LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291113		A. BUNTEN	11/8/2016	10:34:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	008P	WATER BUBBLER RIGHT AUDITORIUM LOBBY		COPPER	ND	MG/L	0.02	EPA 200.8	ICAL BALAN	169291112		A. BUNTEN	11/8/2016	10:32:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	008P	WATER BUBBLER RIGHT AUDITORIUM LOBBY		LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291112		A. BUNTEN	11/8/2016	10:32:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	009P	WATER BUBBLER LEFT 7TH GRADE COMMON AREA		COPPER	0.02	MG/L	0.02	EPA 200.8	ICAL BALAN	169291114		A. BUNTEN	11/8/2016	10:35:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	009P	WATER BUBBLER LEFT 7TH GRADE COMMON AREA		LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291114		A. BUNTEN	11/8/2016	10:35:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	010F	WATER BUBBLER RIGHT 7TH GRADE COMMON AREA		COPPER	0.02	MG/L	0.02	EPA 200.8	ICAL BALAN	169291116		A. BUNTEN	11/8/2016	10:37:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	010F	WATER BUBBLER RIGHT 7TH GRADE COMMON AREA		LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291116		A. BUNTEN	11/8/2016	10:37:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	010P	WATER BUBBLER RIGHT 7TH GRADE COMMON AREA		COPPER	0.03	MG/L	0.02	EPA 200.8	ICAL BALAN	169291115		A. BUNTEN	11/8/2016	10:36:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	010P	WATER BUBBLER RIGHT 7TH GRADE COMMON AREA		LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291115		A. BUNTEN	11/8/2016	10:36:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	011P	WATER BUBBLER LEFT 6TH GRADE COMMON AREA		COPPER	0.02	MG/L	0.02	EPA 200.8	ICAL BALAN	169291117		A. BUNTEN	11/8/2016	10:38:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	011P	WATER BUBBLER LEFT 6TH GRADE COMMON AREA		LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291117		A. BUNTEN	11/8/2016	10:38:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	012F	WATER BUBBLER RIGHT 6TH GRADE COMMON AREA		COPPER	0.02	MG/L	0.02	EPA 200.8	ICAL BALAN	169291119		A. BUNTEN	11/8/2016	10:40:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	012F	WATER BUBBLER RIGHT 6TH GRADE COMMON AREA		LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291119		A. BUNTEN	11/8/2016	10:40:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	012P	WATER BUBBLER RIGHT 6TH GRADE COMMON AREA		COPPER	0.02	MG/L	0.02	EPA 200.8	ICAL BALAN	169291118		A. BUNTEN	11/8/2016	10:39:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	012P	WATER BUBBLER RIGHT 6TH GRADE COMMON AREA		LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291118		A. BUNTEN	11/8/2016	10:39:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	013P	WATER BUBBLER LEFT 8TH GRADE HALLWAY		COPPER	0.03	MG/L	0.02	EPA 200.8	ICAL BALAN	169291120		A. BUNTEN	11/8/2016	10:43:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	013P	WATER BUBBLER LEFT 8TH GRADE HALLWAY		LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291120		A. BUNTEN	11/8/2016	10:43:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	014F	WATER BUBBLER RIGHT 8TH GRADE HALLWAY		COPPER	0.11	MG/L	0.02	EPA 200.8	ICAL BALAN	169291122		A. BUNTEN	11/8/2016	10:45:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	014F	WATER BUBBLER RIGHT 8TH GRADE HALLWAY		LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291122		A. BUNTEN	11/8/2016	10:45:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	014P	WATER BUBBLER RIGHT 8TH GRADE HALLWAY		COPPER	0.14	MG/L	0.02	EPA 200.8	ICAL BALAN	169291121		A. BUNTEN	11/8/2016	10:44:00	22-Dec-16

LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	014P	WATER BUBBLER RIGHT 8TH GRADE HALLWAY	LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291121	A. BUNTEN	11/8/2016	10:44:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	015P	WATER BUBBLER LEFT IN GYM NEAR MAIN DOOR	COPPER	0.03	MG/L	0.02	EPA 200.8	ICAL BALAN	169291123	A. BUNTEN	11/8/2016	10:47:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	015P	WATER BUBBLER LEFT IN GYM NEAR MAIN DOOR	LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291123	A. BUNTEN	11/8/2016	10:47:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	016F	WATER BUBBLER RIGHT IN GYM NEAR MAIN DOOR	COPPER	0.03	MG/L	0.02	EPA 200.8	ICAL BALAN	169291125	A. BUNTEN	11/8/2016	10:48:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	016F	WATER BUBBLER RIGHT IN GYM NEAR MAIN DOOR	LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291125	A. BUNTEN	11/8/2016	10:48:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	016P	WATER BUBBLER RIGHT IN GYM NEAR MAIN DOOR	COPPER	0.06	MG/L	0.02	EPA 200.8	ICAL BALAN	169291124	A. BUNTEN	11/8/2016	10:49:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	016P	WATER BUBBLER RIGHT IN GYM NEAR MAIN DOOR	LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291124	A. BUNTEN	11/8/2016	10:49:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	017P	WATER BUBBLER LEFT IN TECH-ED HALL	COPPER	0.09	MG/L	0.02	EPA 200.8	ICAL BALAN	169291126	A. BUNTEN	11/8/2016	10:53:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	017P	WATER BUBBLER LEFT IN TECH-ED HALL	LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291126	A. BUNTEN	11/8/2016	10:53:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	018F	WATER BUBBLER RIGHT IN TECH-ED HALL	COPPER	0.06	MG/L	0.02	EPA 200.8	ICAL BALAN	169291128	A. BUNTEN	11/8/2016	10:55:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	018F	WATER BUBBLER RIGHT IN TECH-ED HALL	LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291128	A. BUNTEN	11/8/2016	10:55:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	018P	WATER BUBBLER RIGHT IN TECH-ED HALL	COPPER	0.06	MG/L	0.02	EPA 200.8	ICAL BALAN	169291127	A. BUNTEN	11/8/2016	10:54:00	22-Dec-16
LCCA	Marshfield	01710310	Marshfield: Furnace Brook Middle	Public School	018P	WATER BUBBLER RIGHT IN TECH-ED HALL	LEAD	ND	MG/L	0.001	EPA 200.8	ICAL BALAN	169291127	A. BUNTEN	11/8/2016	10:54:00	22-Dec-16