

The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

PORTTYPE	CITY/TOWN	ORG CODE	SCHOOL NAME	SCHOOL TYPE	LOCATION ID	SAMPLE LOCATION NAME	AMPLE COMMENT	ANALYTE NAME	RESULT	OF MEASURE	METHOD DETECTION LIMIT	YTICAL METHOD	ANALYSIS	LAB SAMPLE ID	ANALYSIS COMMENTS	SAMPLER NAME	SAMPLE COLLECTION DATE	LEAD COLLECTION	REPORT DATE
LCCA	Marshfield	01710010	Marshfield: South River	Public School	001F	ROOM 106 FAUCET		COPPER	0.14		MG/L	0.02	EPA 200.8	ICAL BALAN	169290602	J. ZOANKOWSKI	11/8/2016	07:43:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	001F	ROOM 106 FAUCET		LEAD	0.004		MG/L	0.001	EPA 200.8	ICAL BALAN	169290602	J. ZOANKOWSKI	11/8/2016	07:43:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	001P	ROOM 106 FAUCET		COPPER	0.78		MG/L	0.02	EPA 200.8	ICAL BALAN	169290601	J. ZOANKOWSKI	11/8/2016	07:38:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	001P	ROOM 106 FAUCET		LEAD	0.014		MG/L	0.001	EPA 200.8	ICAL BALAN	169290601	J. ZOANKOWSKI	11/8/2016	07:38:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	002P	ROOM 106 BUBBLER		COPPER	0.21		MG/L	0.02	EPA 200.8	ICAL BALAN	169290603	J. ZOANKOWSKI	11/8/2016	07:46:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	002P	ROOM 106 BUBBLER		LEAD	0.009		MG/L	0.001	EPA 200.8	ICAL BALAN	169290603	J. ZOANKOWSKI	11/8/2016	07:46:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	003F	ROOM 104 FAUCET		COPPER	0.15		MG/L	0.02	EPA 200.8	ICAL BALAN	169290605	J. ZOANKOWSKI	11/8/2016	07:52:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	003F	ROOM 104 FAUCET		LEAD	0.007		MG/L	0.001	EPA 200.8	ICAL BALAN	169290605	J. ZOANKOWSKI	11/8/2016	07:52:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	003P	ROOM 104 FAUCET		COPPER	0.53		MG/L	0.02	EPA 200.8	ICAL BALAN	169290604	J. ZOANKOWSKI	11/8/2016	07:50:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	003P	ROOM 104 FAUCET		LEAD	0.042		MG/L	0.001	EPA 200.8	ICAL BALAN	169290604	J. ZOANKOWSKI	11/8/2016	07:50:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	004P	ROOM 104 BUBBLER		COPPER	0.33		MG/L	0.02	EPA 200.8	ICAL BALAN	169290606	J. ZOANKOWSKI	11/8/2016	07:54:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	004P	ROOM 104 BUBBLER		LEAD	0.029		MG/L	0.001	EPA 200.8	ICAL BALAN	169290606	J. ZOANKOWSKI	11/8/2016	07:54:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	005F	WATER COOLER OUTSIDE RM 104		COPPER	0.52		MG/L	0.02	EPA 200.8	ICAL BALAN	169290608	J. ZOANKOWSKI	11/8/2016	07:58:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	005F	WATER COOLER OUTSIDE RM 104		LEAD	0.006		MG/L	0.001	EPA 200.8	ICAL BALAN	169290608	J. ZOANKOWSKI	11/8/2016	07:58:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	005P	WATER COOLER OUTSIDE RM 104		COPPER	0.63		MG/L	0.02	EPA 200.8	ICAL BALAN	169290607	J. ZOANKOWSKI	11/8/2016	07:56:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	005P	WATER COOLER OUTSIDE RM 104		LEAD	0.005		MG/L	0.001	EPA 200.8	ICAL BALAN	169290607	J. ZOANKOWSKI	11/8/2016	07:56:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	006F	ROOM 102 FAUCET		COPPER	0.12		MG/L	0.02	EPA 200.8	ICAL BALAN	169290610	J. ZOANKOWSKI	11/8/2016	08:02:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	006F	ROOM 102 FAUCET		LEAD	0.006		MG/L	0.001	EPA 200.8	ICAL BALAN	169290610	J. ZOANKOWSKI	11/8/2016	08:02:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	006P	ROOM 102 FAUCET		COPPER	0.34		MG/L	0.02	EPA 200.8	ICAL BALAN	169290609	J. ZOANKOWSKI	11/8/2016	08:01:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	006P	ROOM 102 FAUCET		LEAD	0.029		MG/L	0.001	EPA 200.8	ICAL BALAN	169290609	J. ZOANKOWSKI	11/8/2016	08:01:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	007F	STEAM ROOM FAUCET		COPPER	0.23		MG/L	0.02	EPA 200.8	ICAL BALAN	169290612	J. ZOANKOWSKI	11/8/2016	08:11:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	007F	STEAM ROOM FAUCET		LEAD	0.003		MG/L	0.001	EPA 200.8	ICAL BALAN	169290612	J. ZOANKOWSKI	11/8/2016	08:11:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	007P	STEAM ROOM FAUCET		COPPER	0.44		MG/L	0.02	EPA 200.8	ICAL BALAN	169290611	J. ZOANKOWSKI	11/8/2016	08:09:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	007P	STEAM ROOM FAUCET		LEAD	0.010		MG/L	0.001	EPA 200.8	ICAL BALAN	169290611	J. ZOANKOWSKI	11/8/2016	08:09:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	008P	STEAM ROOM BUBBLER		COPPER	0.25		MG/L	0.02	EPA 200.8	ICAL BALAN	169290613	J. ZOANKOWSKI	11/8/2016	08:11:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	008P	STEAM ROOM BUBBLER		LEAD	0.003		MG/L	0.001	EPA 200.8	ICAL BALAN	169290613	J. ZOANKOWSKI	11/8/2016	08:11:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	009F	ROOM 101 FAUCET		COPPER	0.16		MG/L	0.02	EPA 200.8	ICAL BALAN	169290615	J. ZOANKOWSKI	11/8/2016	08:17:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	009F	ROOM 101 FAUCET		LEAD	0.006		MG/L	0.001	EPA 200.8	ICAL BALAN	169290615	J. ZOANKOWSKI	11/8/2016	08:17:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	009P	ROOM 101 FAUCET		COPPER	0.47		MG/L	0.02	EPA 200.8	ICAL BALAN	169290614	J. ZOANKOWSKI	11/8/2016	08:16:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	009P	ROOM 101 FAUCET		LEAD	0.039		MG/L	0.001	EPA 200.8	ICAL BALAN	169290614	J. ZOANKOWSKI	11/8/2016	08:16:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	010P	ROOM 101 BUBBLER		COPPER	0.25		MG/L	0.02	EPA 200.8	ICAL BALAN	169290616	J. ZOANKOWSKI	11/8/2016	08:26:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	010P	ROOM 101 BUBBLER		LEAD	0.012		MG/L	0.001	EPA 200.8	ICAL BALAN	169290616	J. ZOANKOWSKI	11/8/2016	08:26:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	011F	ROOM 103 FAUCET		COPPER	0.19		MG/L	0.02	EPA 200.8	ICAL BALAN	169290618	J. ZOANKOWSKI	11/8/2016	08:30:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	011F	ROOM 103 FAUCET		LEAD	0.006		MG/L	0.001	EPA 200.8	ICAL BALAN	169290618	J. ZOANKOWSKI	11/8/2016	08:30:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	011P	ROOM 103 FAUCET		COPPER	0.37		MG/L	0.02	EPA 200.8	ICAL BALAN	169290617	J. ZOANKOWSKI	11/8/2016	08:29:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	011P	ROOM 103 FAUCET		LEAD	0.032		MG/L	0.001	EPA 200.8	ICAL BALAN	169290617	J. ZOANKOWSKI	11/8/2016	08:29:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	012P	ROOM 103 BUBBLER		COPPER	0.32		MG/L	0.02	EPA 200.8	ICAL BALAN	169290619	J. ZOANKOWSKI	11/8/2016	08:31:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	012P	ROOM 103 BUBBLER		LEAD	0.017		MG/L	0.001	EPA 200.8	ICAL BALAN	169290619	J. ZOANKOWSKI	11/8/2016	08:31:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	013F	ROOM 105 FAUCET		COPPER	0.25		MG/L	0.02	EPA 200.8	ICAL BALAN	169290621	J. ZOANKOWSKI	11/8/2016	08:35:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	013F	ROOM 105 FAUCET		LEAD	0.006		MG/L	0.001	EPA 200.8	ICAL BALAN	169290621	J. ZOANKOWSKI	11/8/2016	08:35:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	013P	ROOM 105 FAUCET		COPPER	0.35		MG/L	0.02	EPA 200.8	ICAL BALAN	169290620	J. ZOANKOWSKI	11/8/2016	08:32:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	013P	ROOM 105 FAUCET		LEAD	0.037		MG/L	0.001	EPA 200.8	ICAL BALAN	169290620	J. ZOANKOWSKI	11/8/2016	08:32:00	15-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	014P	ROOM 105 BUBBLER		COPPER	0.50		MG/L	0.02	EPA 200.8	ICAL BALAN	169290622	J. ZOANKOWSKI	11/8/2016	08:36:00	15-Dec-16







LCCA	Marshfield	01710010	Marshfield: South River	Public School	055P	ROOM 206 BUBBLER		COPPER	0.27		MG/L	0.02	EPA 200.8	ICAL BALAN	169291006		J. ZOANKOWSKI	11/8/2016	11:25:00	22-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	055P	ROOM 206 BUBBLER		LEAD	0.002		MG/L	0.001	EPA 200.8	ICAL BALAN	169291006		J. ZOANKOWSKI	11/8/2016	11:25:00	22-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	056F	WATER COOLER ACROSS THE HALL FROM RM 215		COPPER	0.47		MG/L	0.02	EPA 200.8	ICAL BALAN	169291008		J. ZOANKOWSKI	11/8/2016	11:27:00	22-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	056F	WATER COOLER ACROSS THE HALL FROM RM 215		LEAD	0.001		MG/L	0.001	EPA 200.8	ICAL BALAN	169291008		J. ZOANKOWSKI	11/8/2016	11:27:00	22-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	056P	WATER COOLER ACROSS THE HALL FROM RM 215		COPPER	0.55		MG/L	0.02	EPA 200.8	ICAL BALAN	169291007		J. ZOANKOWSKI	11/8/2016	11:26:00	22-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	056P	WATER COOLER ACROSS THE HALL FROM RM 215		LEAD	0.001		MG/L	0.001	EPA 200.8	ICAL BALAN	169291007		J. ZOANKOWSKI	11/8/2016	11:26:00	22-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	057F	ROOM 208 FAUCET		COPPER	0.19		MG/L	0.02	EPA 200.8	ICAL BALAN	169291010		J. ZOANKOWSKI	11/8/2016	11:30:00	22-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	057F	ROOM 208 FAUCET		LEAD	0.002		MG/L	0.001	EPA 200.8	ICAL BALAN	169291010		J. ZOANKOWSKI	11/8/2016	11:30:00	22-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	057P	ROOM 208 FAUCET		COPPER	0.55		MG/L	0.02	EPA 200.8	ICAL BALAN	169291009		J. ZOANKOWSKI	11/8/2016	11:29:00	22-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	057P	ROOM 208 FAUCET		LEAD	0.005		MG/L	0.001	EPA 200.8	ICAL BALAN	169291009		J. ZOANKOWSKI	11/8/2016	11:29:00	22-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	058P	ROOM 208 BUBBLER		COPPER	0.41		MG/L	0.02	EPA 200.8	ICAL BALAN	169291011		J. ZOANKOWSKI	11/8/2016	11:31:00	22-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	058P	ROOM 208 BUBBLER		LEAD	0.002		MG/L	0.001	EPA 200.8	ICAL BALAN	169291011		J. ZOANKOWSKI	11/8/2016	11:31:00	22-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	059F	ROOM 210 FAUCET		COPPER	0.10		MG/L	0.02	EPA 200.8	ICAL BALAN	169291013		J. ZOANKOWSKI	11/8/2016	11:34:00	22-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	059F	ROOM 210 FAUCET		LEAD	0.001		MG/L	0.001	EPA 200.8	ICAL BALAN	169291013		J. ZOANKOWSKI	11/8/2016	11:34:00	22-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	059P	ROOM 210 FAUCET		COPPER	0.51		MG/L	0.02	EPA 200.8	ICAL BALAN	169291012		J. ZOANKOWSKI	11/8/2016	11:33:00	22-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	059P	ROOM 210 FAUCET		LEAD	0.011		MG/L	0.001	EPA 200.8	ICAL BALAN	169291012		J. ZOANKOWSKI	11/8/2016	11:33:00	22-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	060P	ROOM 210 BUBBLER		COPPER	0.25		MG/L	0.02	EPA 200.8	ICAL BALAN	169291014		J. ZOANKOWSKI	11/8/2016	11:35:00	22-Dec-16
LCCA	Marshfield	01710010	Marshfield: South River	Public School	060P	ROOM 210 BUBBLER		LEAD	0.010		MG/L	0.001	EPA 200.8	ICAL BALAN	169291014		J. ZOANKOWSKI	11/8/2016	11:35:00	22-Dec-16